

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

## **Report of Analysis**

Name: Parkway School

Greenwich Public Schools - Cordes George

290 Greenwich Ave

Greenwich, CT 06830-6521

**Sample Date:** 10/27/2021 7:45 AM

**Receipt Date:** 10/27/2021 2:00 PM

**Report Date:** 10/30/2021

Sample Site: DISTRIBUTION SYSTEM

**Sample ID#:** 275235

Sample Type: Drinking Water

**Sample Source:** PS025 **Sampler:** PD

**PWS ID:** CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
Metals						
Copper	0.06	mg/L	EPA 200.5	0.005	10/28/2021 16:13	TJB
Lead	0.002	mg/L	EPA 200.5	0.001	10/28/2021 16:13	TJB

**Comments:** Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
\* = Above Specified Limit

Report Approved by:

Lab Director

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.