## **Report of Analysis**

Name: Parkway School

Greenwich Public Schools - Cordes George

290 Greenwich Ave

Greenwich, CT 06830-6521

**Sample Date:** 6/23/2021 7:40 AM **Receipt Date:** 6/23/2021 3:20 PM

**Report Date:** 6/24/2021

Sample Site: DISTRIBUTION SYSTEM

**Sample ID#:** 268112

Sample Type: Drinking Water

**Sample Source:** PS017 **Sampler:** PD

**PWS ID:** CT0570212

Parameter	Sample Result	Units	Method	Minimum Detection	Analysis Date	Analyst
Biological Coliform Bacteria e Coli Bacteria	absent absent	none none	SM9223B-04 SM9223B-04	0 0	5/23/2021 16:55 5/23/2021 16:55	KH KH
Inorganic Compounds Chlorine, residual	ND	mg/L	M4500CLG-2.	0.05	5/23/2021 07:40	TJB

**Comments:** Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
\* = Above Specified Limit

Report Approved by:

Lab Director

CT Lic PH-0787 NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.