

Report of Analysis

Name:Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521Sample Date:10/21/2020 6:50 AMReceipt Date:10/21/2020 3:00 PMReport Date:10/23/2020Sample Site:DISTRIBUTION SYSTEM				Sample ID#: Sample Type: Sample Source: Sampler: PWS ID:	Ų	Drinking Water PS011 PD	
Sample Site:	DISTRIBUTIC	N SYSTEM					
Parameter		Sample	Units	Method	Minimum	Analysis	

Parameter	Sample Result	Units	Method	Minimum Detection	Analysis Date	Analyst
Metals						
Copper	0.05	mg/L	EPA 200.5	0.005	10/23/2020	TJB
Lead	0.005	mg/L	EPA 200.5	0.001	10/23/2020	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

Sau

ND = Not Detected * = Above Specified Limit

Τ

Report Approved by: annas Lab Director

CT Lic PH-0787 NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.