## **Report of Analysis**

Name: Parkway School

Greenwich Public Schools - Cordes George

290 Greenwich Ave

Greenwich, CT 06830-6521

**Sample Date:** 7/6/2022 12:20 PM **Receipt Date:** 7/6/2022 3:50 PM

**Report Date:** 7/8/2022

Sample Site: DISTRIBUTION SYSTEM

**Sample ID#:** 289711

Sample Type: Drinking Water

**Sample Source:** PS017 **Sampler:** PD

**PWS ID:** CT0570212

Parameter	Sample Result	Units	Method	RL	Analysis Date	Analyst
Physical						
Color, apparent	5	CU	SM 2120B-01	5	7/6/2022 15:45	BW
Odor	0	TON	SM2150B-2011	0	7/6/2022 15:00	BW/SM
PH	7.5	pН	SM4500HB-2011	0	7/6/2022 16:04	TJB
Turbidity	0.97	NTU	EPA 180.1	0.05	7/6/2022 15:00	BW

**Comments:** Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected \* = Above Specified Limit

Report Approved by:

Lab Director

CT Lic PH-0787

NY Lic 11706

AquaEnvLab.com YorkLab.com 203 270 9973

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.